

Short Form Classification Report No.19108K

PRODUCT

Vulcasteel 1000

SPONSOR

Joris Ide nv

PRODUCT DETAILS

- Rigid face sandwich panel
- 50-200 mm mineral wool insulation
- 100±15 kg/m³ mineral wool insulation
- polyester coating
- PU-joint seal

FIELD OF APPLICATION

- Range of pitches: ≤ 10°,
See annex for fully detailed field of application

CLASSIFICATION

Broof(T4)

STANDARDS

Test standard: CEN/TS 1187-T4

Classification standard: EN 13501-1:2016

SIGNED

APPROVED

For and on behalf of WFRGENT nv

This short form classification report has been drafted according to EGOLF agreement EGA 08rev2:2013 "Application note: clause 5.10 [5.10/1] – Types of test reports used in fire testing". Whilst the test data and classification provided within this short form report was obtained in a test conducted fully in accordance with the standards CEN/TS 1187:2012

, the presentation of the results in this short form report may not satisfy the requirements of those standards and EN ISO/IEC 17025:2005/AC:2006. The presentation of the results in this manner is made by agreement with the sponsor and use of the information herein for product assessment, approval or certification purposes will be restricted.

The full classification report No. **19108H** is available at **Joris Ide nv**

This document is the original version of this report and is written in English. This document may be used only literally and completely for publications. For publications of certain texts, in which this document is mentioned, our permission must be obtained in advance.

The authenticity of the electronic signatures is assured by Belgium Root CA.

Annex: fully detailed field of application

➤ Range of layer 0: Sandwich Panel

Parameter	Factors	Validity of test
Metal facings	a) Colour of coating b) PCS value of 0,94	a) Valid for all colours b) Valid for all coatings in the range 0 to 4 MJ/m ²
Metal facings	Thickness of metal facing excluding organic coatings	0,45-0,90
Seals	Seals (integral with panel)	Valid only for PU seals and for those of 0,0075 or lower PCS
Insulation	Mineral wool density	100±15 kg/m ²
Thickness of panel (mm)	Mineral wool Thickness	50-200mm